

ENVIRONMENTAL HEALTH

1250 Hollipark Drive Idaho Falls, ID 83401 OFFICE (208) 523-5382 FAX (208) 528-0857

FOOD ESTABLISHMENT PLAN REVIEW APPLICATION

Date:				
Name of Food Establishment:				
Address of Food Establishment:				
City/State/Zip Code:				
Person Submitting Plans:				
Contact Email:				
Contact Phone Number:				
Contact Mailing Address:				
City/State/Zip Code:				
Type of Food Establishment: Sit down Restaurant Convenience Store Meat Market Deli Other: Type of Food Establishment: Fast Food Restaurant Supermarket Dakery Mobile Food Unit				

Please attach and submit the following items with this Plan Review Application:

- ✓ Copy of the proposed menu.
- ✓ Floor Plan or blueprint of the proposed food equipment layout, plumbing, lighting and restrooms.
- ✓ List of equipment with make and model numbers. Please include all new and used equipment that you propose for your establishment. Used equipment must be approved by Eastern Idaho Public Health, prior to purchase, to verify compliance with the requirements of the Idaho Food Code.
- ✓ Completed Plan Review and Approval Form.
- ✓ Proof of an Accredited Food Protection Manager certificate of completion from a nationally accredited food safety examination prior to pre-opening inspection.

Non-Refundable Plan Review Application Fee is to be paid at the time this application is submitted.

		EIPH Use Only	
Risk Category:	Medium	High	
Date Paid:	Amount paid:	Receipt #:	_ Received by:



FOOD ESTABLISHMENT PLAN REVIEW AND APPROVAL FORM

New	Remod	leled or Altered		Planning & Zoning Approval			Specialist	
		NAME		ADDRESS			PHONE	
Establishment								
Owner/A	pplicant							
Operator								
Designer	/Equipmer	nt Supplier						
Food	nment Type d Service (ail Market (605)	(Men	Menu: Full menu u changes may requir				Risk Category (Assigned by EH Staff):
Food	d Processo ile (602)	. ,						Low Medium High
Seating (Capacity	Sq. Footage	No. Empl	oyees Per Shift	Date	of Opening	Hours	of Operation
must b of food	e submitte establishr	d to Eastern Idah ment, plumbing a	no Public H and mecha		wand ap ment list	proval. Such	plans sh	remodeling, or alteration ould include a floor plan d specifications.
			_	age system, well and	-			
C. <u>APPR</u>	OVAL of th	<u>ne plans and spe</u>	<u>cifications</u>	is required PRIOR to	the start	of construction	on/remod	<u>del</u> .
accom	D. Submit a <i>Food Establishment License Application</i> thirty (30) days prior to anticipated opening. The license fee must accompany the application. (Sec. 8-302.10-14) (Low risk establishments do not submit fee with application; if the operation is determined to be low risk, it is not required to be licensed nor inspected).							
the est	E. Preoperational/Final inspection: EIPH must be notified of a request for preoperational inspection prior to the opening of the establishment. The preoperational inspection must verify that the food establishment is constructed and equipped in accordance with the approved plans. (Sec. 8-203.10)							
F. Separate approvals: Contact the local zoning, building, fire, plumbing and electrical departments for their requirements. If alcoholic beverages are to be sold, contact the Alcohol Beverage Control Bureau (Idaho Department of Law Enforcement) for approval.								
Plans revi	ewed (date	e):		Approved by:	Env	ironmental He	ealth Spe	ecialist
Note: A	fter plans	are reviewed a	nd approv	ed, applicant must	sign fina	I page accep	ting res	ponsibility and

verifying that it is understood that the establishment will be built in accordance with the approved plans.

A - FOOD PROTECTION

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS
			Convenient and adequate storage, display, and preparation facilities for ice, frozen food (0-10°F), cold foods (<41°F), hot foods (>135°F), other foods and foods on display. (4-301.11). Type and number of cold holding units: Type and number of hot holding units:
			2. Adequate dry food storage provided in a clean, dry location, and not located in locker rooms, toilet rooms, dressing rooms, garbage rooms, mechanical rooms, under sewer lines, under open stairwells. (3-305.11 and 12)
			3. Storage provision to keep all food in non-waterproof containers a minimum of 6" above floor. Bare wood shelving allowed only in dry goods storage area, unopened foods. (3-305.11)
			4. Provision for attached thermometers for all refrigerators, freezers and heat units. (4-204.112)
			 Sneeze guards properly designed on self-serve hot/cold buffets/bars. (Measure 54" to 60" from floor to represent customer mouth height. Guard must block line between mouth and food on display, including end plates) (3-306.11)
			6. Dipper wells provided for ice cream scoops (frozen desserts). (3-304.12(D)

Co	m	m	۵	n	te	
CU	,,,	,,,	E	,,	LΟ	

B-FOOD EQUIPMENT AND UTENSILS

D-100D L	QUIPMENT	ANDU	I I
FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS
			ALL FOOD CONTACT EQUIPMENT must be safe, durable, corrosion-resistant and nonabsorbent; sufficient in weight and thickness to withstand repeated warewashing; finished to be smooth and easily cleanable; resistant to pitting, chipping or distortion; and not allow the migration of deleterious substances or impart colors, odors or tastes to food. (4.101.11)
			Food equipment certified by an ANSI-accredited program meets this standard. (4-205.10)
			2. All used or existing equipment requires approval prior to installation and be in good repair and capable of being maintained in a sanitary condition. (8-101.10)
			3. Counter-type equipment: movable, on 4"+ legs; or sealed to counter. (4-402.12) Floor-type equipment: movable, on 6"+ legs; or sealed to floor/base. (4-402.12)
			4. Space between units or walls closed; or opened sufficient distance for easy cleaning along sides, behind or above. (4-402.11)
			5. Aisles - sufficient width: minimum 36"; 42" for two or more workers; wider for mobile equipment. (Uniform Building Code)
			6. Raw food prep table and food preparation sink provided (if applicable per menu). Prep sinks must be indirectly wasted to sewer. (3-302.11)
			DISH AND UTENSIL WASHING AND SANITIZATION
			7. Adequately sized multi-use utensil and pot wash sinks for manual dishwashing. (4-301.12)
			8. Properly designed drainboards or dish tables provided for soiled and clean utensils. (4-301.13)
			9. Dish machine type: Low temperature□, chemical feed□ or High temperature□, equipped to automatically dispense detergents and sanitizers, with low level alarm. (4-204.117) 1/4" IPS (Iron pipe size) valve for pressure gauge required on the hot water supply line for the hot water sanitizing rinse. (4-204.118)
			Warewasher machine(s) provided with a readable data plate indicating the machine operating specifications: Temperature, pressure and conveyor or cycle speed. Machine make: Model number: (4-204.113)

	11. Accurate temperature measuring devices that indicates the temperature of the water in the wash and rinse compartments of warewashing machines. (4-204.115)
	12. If no warewashing sinks or mechanical warewashing machines are provided, then only single-use kitchenware and tableware may be used by food employees and consumers. (4-502.12)
	13. Storage for cleaned equipment, utensils, and single-use and single-service articles shall be in a clean, dry location not exposed to splash or contamination, and 6"+ above floor. (4-903.11)

Comments:

C - WATER SUPPLIES AND SEWAGE DISPOSAL

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS		
			Public water supply (Name of approved supplier/system):(5-101.11)		
			2. Non-municipal supply type:		
			Hot and cold water provided under pressure to all fixtures, and hot water system sufficient to meet the peak hot water demands throughout the food establishment. (5-103.11 - 12)		
			4. 140°F water capacity gallons. (5-l03.11 - adequate) Recovery rate: gallons/°F rise		
			5. 180°F water and/or booster heater for high temp dish machines. (4-501.112)		
			6. Public sewer - name:(5-403.11)		
			7. Septic system or other type disposal. PLANS MUST BE SUBMITTED AND APPROVED PRIOR TO FINAL INSPECTION. (Rules for Subsurface Disposal call for <u>AIR COOLED</u> ice making equipment, refrigeration equipment and wok ranges.) (5-403.11, 12)		
			8. Grease interceptor or trap sized in accordance to Uniform Plumbing Code (UPC), and located to be easily accessible for cleaning. (5-402.12)		

Comments:

D - PLUMBING

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS
			All plumbing of safe materials, sized, installed in accordance with the Uniform Plumbing Code (UPC). (5-201.11, 5-202.11)
			Water flushed walk-in box floor sloped to proper drain. Drain outside walk-in box. Condensate wastes to floor sink or approved hub drain outside walk-ins. (UPC 801.2)
			3. Floor sinks must be 50% exposed if under equipment, for cleaning. (UPC 804.1) Floor sinks or drains not enclosed in cabinets - may have unseen flooding, humidity damage. Box out with cabinet base and toe kick. (4-202.17)
			4. Dipper wells: air gap supply line; open (indirect) drain (UPC 801.2.3d)
			5. Dishwasher: air gap fill, vacuum breaker rinse line; open (indirect) drain. (5-402.11) (No direct drain unless in compliance with 5-402.11B)
			6. Food sinks for draining/washing ready-to-serve food: air-gapped indirect drain. (UPC 801.2.3)
			7. Garbage grinder/disposal/drainboard scupper: vacuum breaker supply water. (UPC 603)
			8. Ice bin and machine: open (indirect) drain; air gap supply line to reservoir. (UPC 801.2)

Janitorial faucets/hose bibs/threaded faucets: vacuum breaker required if threaded faucet for hoses. (UPC 603.4.7)
10. Soap dispensers when located on approved faucets: Approved backflow preventer required. (UPC 603)
 Soda fountain water line to carbonator: Reduced pressure device required, installed upstream from a carbonating device and downstream from any copper in the water supply line. (5-203.15) (UPC603.4.13) (6th Edition Cross-Connection Manual)
12. Hood, self -clean type: Approved backflow protection required. (UPC 603)

BACKFLOW AND BACK SIPHONAGE PROTECTION FOR: (UPC 603.0 and 801.0) Backflow or backsiphonage prevention devices installed on water supply lines shall meet ASSE standards for construction, installation, maintenance and testing for the specific application and type of device. (5-202.14) Air gaps between the water supply inlet and the equipment or fixture shall be twice the diameter of the supply inlet and not less than 1". (5-202.23)

E - TOILET AND HAND-WASHING FACILITIES FOR PATRONS AND EMPLOYEES

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS
			Patron toilet rooms located so that customers do not pass through food preparation, warewashing or food storage areas. (2-103.11)
			2. Employee toilet rooms conveniently located and accessible for employee use. (6.402.11)
			3. Fully enclosed toilet rooms, self-closing doors. (6-202.14)
			4. Adequate ventilation:WindowMechanical (6.304.11)
			Hand-washing lavatory sinks with hot and cold water through mixing faucets. (5-202.12) (15-second water flow required if faucet has automatic shut-off)
			Adequate number of urinals, water closets and lavatories in toilet rooms. (5-203.12) FemaleMale
			7. Waste receptacles provided. (5-501.16) Covered waste receptacles required for disposal of sanitary napkins in toilet rooms used by females. (5-501.17)
			8. Hand-washing cleanser, paper towels, hand dryers or continuous towel rollers provided for handsinks. (6-301.11, 12)

Comments:

F - EMPLOYEE HAND-WASHING FACILITIES

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS	
			A number of hand-washing lavatories necessary for their convenient use shall be provided. (5-203.11) (Required in food preparation area, dishwashing area, wait stations, and restrooms)	
			2. Hand cleanser, paper towels, hand dryers or continuous roll towels provided for handsinks.	

Comments:

G - GARBAGE AND REFUSE

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS	
			1. Inside containers adequate, convenient, durable, insect- and rodent-resistant, leakproof and nonabsorbent. (5-501.13) Floor, wall and ceiling in garbage storage areas must be smooth, durable and easily cleanable. (6-101.11)	
			2. Outside receptacles for refuse, recyclables and returnables shall be designed to have tight-fitting lids, doors or covers. (5-501.15) Outside garbage area is concrete or asphalt and is smooth, durable and sloped to drain. (5-501.11)	

				3.	At least one mop sink or service sink or curbed cleaning facility equipped with a floor drain shall be provided and conveniently located for cleaning of mops and for the disposal of mop water or similar liquid waste. (5-203.13)
4. Mop/broom storage provided, rack or hoo		4.	Mop/broom storage provided, rack or hooks for hanging mops to dry. (6-501.16)		

Comments:

H - VERMIN CONTROL

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS	
			Outer openings screened (vents, windows) with 16 mesh or smaller screen; outer doors self-closing. (6-202.15)	
			2. Air screens, plastic curtains provided on doors if needed to control flying insects. (6-202.15)	
			3. Building rodent proof. Wall openings closed. (6-202.15)	

Comments	:
----------	---

I - STRUCTURAL DESIGN AND MATERIALS

AREA	FLOOR*	BASE**	WALL***	CEILING***
Dining Area				
Kitchen				
Walk-in Refrigerator and Freezer				
Warewashing Area				
Food Storage Areas				
Toilet Rooms****			4 foot wainscot	
Locker Rooms/Areas				
Mop/Service Area			4 foot wainscot	
Outside Areas (6-102.11) -	- walking and driving a	reas surfaced to minimize	e dust and prevent muddy	conditions.

Comments:

^{*}Floors and floor coverings shall be durable sealed concrete, terrazzo, quarry tile, ceramic tile, durable grades of vinyl or plastic tile or tight-fitting wood impregnated with plastic. Floors of nonrefrigerated dry food storage need not be sealed. Carpet may not be used in food preparation or processing areas, walk-in refrigerators, warewashing areas, refuse storage rooms and toilet rooms where hand-washing lavatories, urinals and toilets are located. (6-101.11)

^{**}Base - junctures between walls and floors shall be coved and constructed so that no seam will be open more than 1/32 inch. Where waterflush cleaning methods, the floor shall be graded to a drain, coved and sealed. (6-201.13)

^{***}Walls, wall coverings and ceilings shall be nonabsorbent, finished and sealed to be easily cleanable and light colored in food preparation and processing areas, food storage areas, warewashing areas, walk-in refrigerators, dining areas, food display areas, retail sales areas, food service areas, dressing rooms, locker rooms, toilet rooms, servicing areas, and refuse storage rooms. Walls and ceilings of nonrefrigerated dry food storage areas and rooms need not be finished and sealed; ceiling studs, rafters may be exposed and rough-surfaced materials used in dining areas. Acoustical materials shall not be used in food preparation and processing rooms, warewashing rooms and refuse storage rooms. (6-201.11)

^{****}Floors and walls in restrooms shall be smooth, hard, nonabsorbent surfaces such as Portland cement, concrete, ceramic tile or other approved material. Floor material must extend upward onto the walls at least 5 inches. Walls shall be of said materials not adversely affected by moisture. Bars, paper dispensers, soap holders that are provided on or within walls shall be installed and sealed to protect structural elements from moisture. (Uniform Building Code, 807.1 & 2)

J - LIGHTING, Artificial/Natural

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS		
			All surfaces where food employees are working with food or with utensils such as knives, slicers, grinders or saws - 50 foot candles. (6-303.11)		
			2. At surfaces where food is provided for consumer self-service such as buffets and salad bars, and at hand-washing, warewashing, equipment/utensil storage areas and toilet rooms - 20 foot candles. (6-303.11)		
			3. All other areas, 30" from floor - 10 foot candles. (6-303.11i)		
			4. Light shielding provided in all food handling, warewashing, open food storage, utensil storage and single service storage areas. (6-202.11)		
			5. Lights in hoods UL approved. (National Fire Protection Association)		

Co	m	m	ei	nts

K - VENTILATION

	* APRILIEDITOR						
FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS				
			 Sufficient ventilation to all rooms to keep them free of excessive heat, steam, grease, vapors, condensation, obnoxious odors and fumes which are a result of the food operation. (6-304.11) Commercial kitchen hoods shall be designed, constructed and installed according to the Uniform Mechanical and Building Codes. (UMC Section 507 and 508) 				
			Type of hood:Type I (Grease filters/fire suppression)Type II (No grease produced) Wall hungIslandBack-shelf ventilatorSelf-cleaning				
			Drawings provided: elevated drawing of hood and duct system;floor plan showing hood, make-up air registers, equipment				
			3. Hood construction: 22 gauge-Type I, 24 gauge-Type II. Welded joints & seams. (UMC 508.2) Six-inch overhang extending beyond cooking equipment. Hood exhaust outlets terminating two feet above roof, ten feet from any air intake openings. (UMC 507.11)				
			4. Restrooms vented, or with openable, screened windows (to keep them free of objectionable odors). (6-304.11)				

Comments:

L - OTHER OPERATIONS

FINAL	PLANS	N/A	DESCRIPTION OF CRITERIA AND/OR REQUIREMENTS	
			Dressing rooms or areas provided if employees change their clothes in the establishment. Lockers provided for storage of employees possessions. (6-305.11)	
			2. Cleaning materials/pesticides are not stored near food, food contact equipment or containers, paper products. Separate storage, closed cabinets for pesticides. (7-201.11)	
			3. A private home, a room used as living or sleeping quarters, or an area directly opening into a room used as living or sleeping quarters may not be used for conducting food establishment operations. (6-202.111) Living or sleeping quarters located on the premises of a food establishment shall be separated from rooms and areas used for food establishment operation by complete partitioning and solid self-closing doors. (6-202.111 and 112)	
			4. Laundry equipment (washer/dryer) not located in area with exposed food, clean equipment, utensils, or unwrapped single-service and single-use articles. (4-401.11.C)	
			5. Utility service lines and pipes not installed on the floors, nor unnecessarily exposed on walls or ceilings; those that are exposed shall not obstruct or prevent cleaning of the floors, walls or ceilings. (6-201.12)	

Con	nme	nts
-----	-----	-----

APPROVAL of the plans and specifications does not constitute endorsement or acceptance of the completed establishment, structure or equipment installation. Any changes or deviations from these approved plans must be submitted in writing and approved by EIPH.

IF NOT OTHERWISE MENTIONED, THE RULES IN IDAPA 16.02.19 <u>FOOD SAFETY AND SANITATION STANDARDS</u> <u>FOR FOOD ESTABLISHMENTS</u> (IDAHO FOOD CODE) SHALL APPLY.

I have read and understand and agree to comply with the above listed requirements and accept responsibility for any changes needed when not in compliance.

Signed:		
Firm/Company:_		
Date:		

Key to Abbreviations:

NFPA – National Fire Protection Association IDAPA – Idaho Administrative Procedures Act ASSE – American Society of Safety Engineers ANSI – American National Standards Institute

UBC – Uniform Building Code
UMC – Uniform Mechanical Code
UPC – Uniform Plumbing Code
UL – Underwriters' Laboratories

EIPH Use Only
Eastern Idaho Public Health Reviewer:
Date(s) and Time Spent (List Below):
Time of Initial Plan Review:
Correction letter, phone call or meeting:
Time on Reviewing Revised Plans:
Other:
Approval letter, phone call or meeting: